


# IECsoft PPA Series PC Software IEC61000 Harmonics Flicker and EMC Testing


PPA55x1 series power analyzers combined with a unique level of ISO17025 accredited calibration for IEC61000 Harmonic and Flicker functions, have made N4L a leading test solution supplier in this field.

Developed to reflect the increasing complexity of these standards and the ongoing changes they involve, IECsoft PC software has become a reference against which others are compared.




### Intuitive user interface

With a clear sequence of operation stages, from first selecting what a user wishes to do, then confirmation of the equipment under test that will be presented in automatic report generation, IECsoft guides the user through a test process.



### Choice of standards and revisions

Within both Harmonic and Flicker test modes, a user has the option to select prevailing standards or those awaiting a stability date, simplifying the comparison of test results made previously.




### Logical option sequence

Having selected the test mode, for example Harmonics, associated options are presented.

In this example, harmonic test 'class' options are displayed and selected with radio buttons.

### Real time data presentation

Unlike many IEC61000 systems that rely on PC sample processing, IECSoft presents real time measured results from a PPA55 series power analyzer. This PPA+IECSoft combination allows real time measurement presentation without excessive PC processing or memory constraints.



**Flexible presentation**

The optimum data presentation format will depend upon many things, not least user preference.

IECSoft allows users to switch between Real Time Data, Graph, or Table view during a test.

Frequency	Vrms	Arms	Watts	Power Factor	Voltage CF	Current CF
50.000 Hz	230.69 V	702.78 mA	77.383 W	0.4773	1.4087	3.6616
Current THD	THC	THC Avg	H 1	H 2	H 3	H 4
181.5225%	615.23 mA	613.90 mA	339.03 mA	2.6955 mA	319.57 mA	2.9158 mA
H 5	H 6	H 7	H 8	H 9	H 10	H 11
298.75 mA	3.2837 mA	263.79 mA	3.0760 mA	224.69 mA	3.1800 mA	181.23 mA
H 12	H 13	H 14	H 15	H 16	H 17	H 18
3.0078 mA	137.30 mA	2.9855 mA	95.415 mA	2.9770 mA	58.901 mA	2.9591 mA
H 19	H 20	H 21	H 22	H 23	H 24	H 25
29.351 mA	2.9070 mA	14.341 mA	2.6742 mA	19.347 mA	3.0406 mA	25.773 mA
H 26	H 27	H 28	H 29	H 30	H 31	H 32
2.8979 mA	27159 mA	2.8826 mA	24.585 mA	2.5394 mA	18.573 mA	3.0655 mA
H 33	H 34	H 35	H 36	H 37	H 38	H 39
11.479 mA	3.0047 mA	5.6687 mA	2.9521 mA	5.0438 mA	2.9120 mA	7.9813 mA
H 40	POHC	POHC Max	Harmonics	Source	Repeatability	
2.9041 mA	56.803 mA	57.212 mA	PASS	PASS	PASS	

Watts	Power Factor	Voltage CF	Current CF
77.342 W	0.4769	1.4100	3.6107
H 1	H 2	H 3	H 4
338.48 mA	2.4474 mA	319.70 mA	3.1050 mA
H 8	H 9	H 10	H 11
3.0816 mA	224.75 mA	3.0699 mA	181.29 mA
H 12	H 13	H 14	H 15
2.9771 mA	137.78 mA	3.2675 mA	95.974 mA
H 16	H 17	H 18	H 19
2.9527 mA	59.614 mA	3.1510 mA	30.081 mA
H 20	H 21	H 22	H 23
2.8400 mA	14.725 mA	3.1618 mA	19.597 mA
H 24	H 25	H 26	H 27
3.1360 mA	25.789 mA	2.7486 mA	27.653 mA
H 28	H 29	H 30	H 31
3.2454 mA	24.678 mA	3.2348 mA	18.970 mA
H 32	H 33	H 34	H 35
2.7811 mA	5.5470 mA	2.9301 mA	5.0507 mA
H 36	H 37	H 38	H 39
3.0310 mA	8.3758 mA	57.368 mA	FAIL
POHC Max	Harmonics	Source	
		PASS	

**Real time test status**


With 'Real Time Data' view, colour coding gives an instant status of individual harmonics relative to their respective limits, PASS or FAIL up to this moment in time, plus verification of voltage source compliance, which is needed for a valid test.

**Harmonic Test summary sheet**

All measurement data taken during a test is recorded and available in an Excel format, so users can review all test detail.

The first page of this report is a summary sheet, confirming the overall test result with product and primary test data.

Instrument Details		
Instrument Model	PPA5531	
Serial Number	166-00914	
Firmware Version	2.185	
N4L Calibration Date	07th July 2022	
Instrument Version	Standard	
Source Details		
Source Model	N4A03	
Source Serial	911-11932	
Source Frequency	50.000Hz	
Source Voltage RMS	230.000V	
Source Settling Time	10.0's	
Test Settings		
Class	Class A	
Mode	Measured	
Equipment Under Test		
Brand	N4L	
Model	Z100	
Serial	P1234	
Impedance Network ID	IMP001	
Test Conditions		
	User Entered	Measured
Rated Voltage	230.000V	230.688V
Rated Current	750.000mA	702.385mA
Rated Frequency	50.000Hz	50.000Hz
Rated Power	172.500W	77.423W
Additional Test Information		
Measured Power Factor	0.478	
Max Current THD	182.48%	
Average THC	617.572mA	
Max Power	77.778W	
Max F.Current	340.714mA	
Average F.Current	338.956mA	
Peak Current Range	30A	
Test Duration	1.0 minute	
Additional Test Details		
Operator	KAR	
Lab Name	N4L	
Location	LAB1	
Notes	Harmonic Class A test data	
Signature		
Results	Phase 1: PASS	



**Flicker Inrush**

Limiting the chance of user error when making inrush tests, IECSoft presents an intuitive progress plot in addition to measurement results as each of 24 tests are made.

At each test stage, **WAIT**, **START DUT** and **STOP DUT** displays guide the user through the test process.

**Real time Flicker storage**


Correct measurement of Flicker functions requires gapless sampling of half cycle Vrms i.e. 100 measurements per second @ 50Hz and 120 measurements per second @ 60Hz. The PPA processes instantaneous flicker sensation at full speed, then sends derived PST and PLT plus captured 'D' events to IECSoft for logging and presentation.

IECSoft v2.7.1 USB,PPA5531,166-00914,2.185.ag LAN,N4A03,91J-11932,1.34

Data ...	Phase	Time	Frequency [...]	Vrms (V)	Pinst	Pinst max	PSTO	PST	PLT	D	Dmax (%)	Dc (%)	Tmax (s)
378	1	+00:01:56.084	49.9999	229.9211	0.0008	0.7073	0.1842	0.1574	0.1574	0.0011	0.9788	0.0271	0.0000
379	1	+00:01:56.381	49.9999	229.9194	0.0007	0.7073	0.1839	0.1574	0.1574	0.0040	0.9788	0.0271	0.0000
380	1	+00:01:56.693	49.9999	229.9197	0.0006	0.7073	0.1837	0.1574	0.1574	0.0162	0.9788	0.0271	0.0000
381	1	+00:01:57.021	50.0005	229.9194	0.0005	0.7073	0.1834	0.1574	0.1574	0.0074	0.9788	0.0271	0.0000
382	1	+00:01:57.323	50.0007	229.9189	0.0006	0.7073	0.1832	0.1574	0.1574	0.0174	0.9788	0.0271	0.0000
383	1	+00:01:57.635	50.0001	229.9189	0.0006	0.7073	0.1830	0.1574	0.1574	0.0193	0.9788	0.0271	0.0000
384	1	+00:01:57.932	50.0006	229.9199	0.0006	0.7073	0.1828	0.1574	0.1574	0.0239	0.9788	0.0271	0.0000
385	1	+00:01:58.229	49.9999	229.9209	0.0009	0.7073	0.1826	0.1574	0.1574	0.0209	0.9788	0.0271	0.0000
386	1	+00:01:58.526	49.9996	229.9219	0.0007	0.7073	0.1824	0.1574	0.1574	0.0226	0.9788	0.0271	0.0000
387	1	+00:01:58.843	50.0004	229.9236	0.0011	0.7073	0.1822	0.1574	0.1574	0.0079	0.9788	0.0271	0.0000
388	1	+00:01:59.140	49.9998	229.9231	0.0007	0.7073	0.1820	0.1574	0.1574	0.0199	0.9788	0.0271	0.0000
389	1	+00:01:59.453	50.0011	229.9253	0.0007	0.7073	0.1818	0.1574	0.1574	0.0220	0.9788	0.0271	0.0000
390	1	+00:01:59.765	50.0000	229.9250	0.0008	0.0008	0.0823	0.1817	0.1704	0.0089	0.9788	0.0271	0.0000
391	1	+00:02:00.0...	49.9999	229.9255	0.0007	0.0008	0.0823	0.1817	0.1704	0.0087	0.9788	0.0271	0.0000
392	1	+00:02:00.3...	49.9998	229.9270	0.0006	0.0008	0.0823	0.1817	0.1704	0.0153	0.9788	0.0271	0.0000
393	1	+00:02:00.7...	49.9996	229.9272	0.0008	0.0010	0.0823	0.1817	0.1704	0.0169	0.9788	0.0271	0.0000
394	1	+00:02:01.0...	50.0002	229.9268	0.0009	0.0010	0.0823	0.1817	0.1704	0.0014	0.9788	0.0271	0.0000
395	1	+00:02:01.302	50.0001	229.9250	0.0008	0.0010	0.0823	0.1817	0.1704	0.0058	0.9788	0.0271	0.0000
396	1	+00:02:01.614	49.9999	229.9243	0.0007	0.0010	0.0823	0.1817	0.1704	0.0069	0.9788	0.0271	0.0000
397	1	+00:02:01.911	49.9999	229.9243	0.0006	0.0010	0.0823	0.1817	0.1704	0.0032	0.9788	0.0271	0.0000
398	1	+00:02:02.2...	50.0005	229.9236	0.0005	0.0010	0.0823	0.1817	0.1704	0.0040	0.9788	0.0271	0.0000
399	1	+00:02:02.5...	49.9999	229.9243	0.0006	0.0010	0.0823	0.1817	0.1704	0.0038	0.9788	0.0271	0.0000
400	1	+00:02:02.822	50.0004	229.9233	0.0005	0.0010	0.0823	0.1817	0.1704	0.0123	0.9788	0.0271	0.0000
401	1	+00:02:03.118	50.0003	229.9238	0.0005	0.0010	0.0823	0.1817	0.1704	0.0103	0.9788	0.0271	0.0000
402	1	+00:02:03.431	49.9998	229.9241	0.0006	0.0010	0.0823	0.1817	0.1704	0.0066	0.9788	0.0271	0.0000
403	1	+00:02:03.743	49.9991	229.9231	0.0008	0.0010	0.0823	0.1817	0.1704	0.0264	0.9788	0.0271	0.0000
404	1	+00:02:04.0...	50.0001	229.9243	0.0006	0.0010	0.0823	0.1817	0.1704	0.0139	0.9788	0.0271	0.0000
405	1	+00:02:04.357	49.9998	229.9233	0.0005	0.0010	0.0823	0.1817	0.1704	0.0200	0.9788	0.0271	0.0000
406	1	+00:02:04.643	50.0001	229.9226	0.0008	0.0010	0.0823	0.1817	0.1704	0.0215	0.9788	0.0271	0.0000
407	1	+00:02:04.9...	49.9998	229.9226	0.0008	0.0010	0.0823	0.1817	0.1704	0.0081	0.9788	0.0271	0.0000
408	1	+00:02:05.252	49.9996	229.9229	0.0006	0.0010	0.0823	0.1817	0.1704	0.0138	0.9788	0.0271	0.0000
409	1	+00:02:05.554	49.9996	229.9224	0.0006	0.0010	0.0823	0.1817	0.1704	0.0207	0.9788	0.0271	0.0000
410	1	+00:02:05.872	49.9997	229.9214	0.0005	0.0010	0.0823	0.1817	0.1704	0.0127	0.9788	0.0271	0.0000
411	1	+00:02:06.184	50.0003	229.9209	0.0007	0.0010	0.0823	0.1817	0.1704	0.0157	0.9788	0.0271	0.0000

Control: Clear Inrush View: IFS Graph Real Time PST Graph Table Results Phase 1 Data: Total Elapsed Time: 0:00:03:00 / 0:00:03:00 PST Elapsed Time: 0:00:01:00 / 0:00:01:00 PST: 3 / 3

Source Status: OFF SHUTDOWN SOURCE



### Flicker results

While long term flicker testing requires a huge number of voltage measurements from which all other parameters are derived, the resulting pass/fail criteria involves a relatively simple report.

While not shown here, IFS and PST Sum Probability graphs are also presented in Flicker Test results.


21st August 2023 - 16:17:39		Ph:1 Page 1/4	IECSoft v2.7
		<b>IEC61000-3-3:2013+AMD1:2017+AMD2:2021+COR1:2022</b>	
		<b>Flickermeter</b>	
<b>Instrument Details</b>			
Instrument Model	PPA5531		
Serial Number	166-00914		
Firmware Version	2.185		
N4L Calibration Date	07th July 2022		
Instrument Version	Standard		
<b>Source Details</b>			
Source Model	N4A03		
Source Serial	91J-11932		
Source Frequency	50.000Hz		
Source Voltage RMS	230.000V		
<b>Test Settings</b>			
Class	Voltage		
Mode	Normal (4.0%)		
Peak Current Range	100A		
PST	1 minutes		
PLT	3 PSTs		
<b>Equipment Under Test</b>			
Brand	N4L		
Model	Z100		
Serial	P1234		
Impedance Network ID	IMP001		
<b>Test Conditions</b>			
	<b>User Entered</b>	<b>Measured</b>	
Rated Voltage	230.000V	229.927V	
Rated Current	750.000mA	N/A	
Rated Frequency	50.000Hz	50.000Hz	
Rated Power	172.500W	N/A	
D max	0.9788% (Limit: 4.0%)		
T max	0.0000 s (Limit: 0.5 s)		
DC max	0.0271% (Limit: 3.3%)		
Inrush Test	0.2995% (Limit: 4.0%)		
Inrush Results	Phase1: Pass		
<b>Additional Test Details</b>			
Operator	KAR		
Lab Name	N4L		
Location	LAB1		
Notes	Flicker and Inrush test data		
Signature			
<b>Results</b>	<b>Phase1: PASS</b>		

### Flicker Test summary sheet

All measurement data taken during a test is recorded and available in an Excel format, so users can review all test detail.

The first page of this report is a summary sheet, confirming the overall test result with product and primary test data.






## EMC Susceptibility

Susceptibility tests involve the generation of defined mains disturbance, during which the behaviour of a device under test is observed.

IECSoft provides an easy and versatile sequence builder from which a test Schedule can be produced.



Test	Status	Action
0.00% during 10.0 cycles at 0 deg	Complete	Review, Retest
50.00% during 20.0 cycles at 0 deg	Complete	Review, Retest
50.00% during 10.0 cycles at 180 deg	Complete	Review, Retest
0.00% during 10.0 cycles at 0 deg	Pending...	Test Now
0.00% during 5.0 cycles at 0 deg	Pending...	Test Now
0.00% during 5.0 cycles at 180 deg	Pending...	Test Now
50.00% to 100.00% over 10.0 cycles at 0 deg	Pending...	Test Now
25.00% to 75.00% over 15.0 cycles at 0 deg	Pending...	Test Now
50.00% to 100.00% over 10.0 cycles at 180 deg	Pending...	Test Now

## Reports and Fast Switching

Since the outcome of these tests relates to the behaviour of a DUT, it is the responsibility of a user to state this on a report and there are no measured 'results' as seen in Harmonic and Flicker testing.

Note: Latest revisions of susceptibility standards include fast switch speed and timing which may require external switch hardware that is not presently supported by N4L.

## Summary:

Standalone executable PC program for Full Compliance\*<sup>1</sup> **Harmonics and Flicker** testing to **IEC61000-3-2/12** (Harmonics) and **IEC61000-3-3/11** (Flicker)

\*<sup>1</sup> When used together with Newtons4th PPA(Analyzer)+IMP(Impedance)+N4A(Source)

**EMC Susceptibility** Testing to:

**IEC61000-4-11**\*<sup>2</sup>, **IEC61000-4-13**, **IEC61000-4-14**, **IEC61000-4-17**, **IEC61000-4-28**,  
**IEC61000-4-29**\*<sup>2</sup>, **IEC61000-4-34**\*<sup>2</sup>

\*<sup>2</sup> Full compliance requires external switching, please contact us for more information

*Minimum System Requirements:* OS: Windows XP SP3, Processor: 233MHz, RAM: 1GB

*Recommended System Requirements:* OS: Windows 11 Processor: 1GHz 2+ cores RAM: 4GB